

From: [Pimpare, Justin](#)
To: [Weidman, Rebecca](#)
Subject: RE: Clinton WWTP
Date: Sunday, December 8, 2019 8:40:00 PM

I got your voicemail and will call you in the morning. This could be from a screen printer or anyone who obviously uses dye? Can you focus in on any user – and it may not be a significant industry – that uses dye in the operation? Talk to you in am
Jay

From: Weidman, Rebecca <Rebecca.Weidman@mwra.com>
Sent: Friday, December 06, 2019 1:40 PM
To: Pimpare, Justin <Pimpare.Justin@epa.gov>
Subject: Clinton WWTP

Hi Jay,

We were out at the Clinton WWTP on Wednesday collecting local limits samples. We had a new sample associate on the sampling team, so as they were packing up for the day, they took a little tour of the facility and came across the attached picture (Image3). The picture is the influent coming into the plant from Clinton. The wastewater was bright red with a slight smell of styrene. Samples collected are pinkish-the coloring can be removed via filtration, but did not otherwise come out of solution. We are in the process of visiting all of the industries in Clinton...If you have any thoughts, I would love to hear them!

Thanks,

Becky

Rebecca Weidman

Director, Toxic Reduction and Control
Massachusetts Water Resources Authority

2 Griffin Way

Chelsea, MA 02150

617-305-5633

Rebecca.Weidman@mwra.com